


Wastewater Utility 2022 Monthly Report



Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
Total MG Treated Effluent 2023	119.40												119.4
Total MG Treated Effluent 2022	107.08	132.88	140.54	120.85	123.71	86.77	72.59	84.83	81.02	69.45	67.96	77.22	1164.90
Total Monthly Precipitation 2023	3.40												3.40
2023 Monthly Percent Capacity Actual Design Flow 4.0 MGD	96%												96%

Sewer Crew Activities	Plant Crew Activities
<ol style="list-style-type: none"> 1. Performed 7 lateral inspections. 2. Completed routine maintenance and lift station checks. 3. Responded to 21 service calls, had several for lift station issues. 4. Continued cleaning up brush from the Davis Road site near the FOP lodge. 5. Serviced equipment. 6. Participated in Trench/Excavation competent person training. 7. Cleaned 4400 feet of mainlines. 8. Continued cleaning and jetting catch basins. 9. Repaired/replaced 7 catch basins. 10. Installed 100 feet of storm main. 	<p style="text-align: center;">Sludge Pressed / Gallons: 970,900</p> <p>Plant Operations and Maintenance:</p> <ol style="list-style-type: none"> 1. Completed required monthly maintenance. 2. Hauled out 1070 tons of bio-solids. 3. Pulled Influent Pump #1 and sent in for repair. 4. Replaced the air cylinder and repaired the air valve on Sludge Pump #1 and repaired the air valve on Sludge Pump #4 5. Drained Primary #1 due to sludge pump issue. 6. Repaired hydraulic line on the loader. 7. Serviced the plant bobcat skidsteer.

Monthly Overtime					
WWTP Operators			Collection System Operators		
Scheduled: weekends,	Emergency Call Ins	Other: Snow Removal	Unscheduled	Emergency Call Ins	Other: Snow Removal
51.5	0	2	21	16	0
Total Dept. Overtime:		90.5			