
Wastewater Utility 2023 Monthly Report





Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
Total MG Treated Effluent 2023	119.40	96.16	164.80	95.29									475.65
Total MG Treated Effluent 2022	107.08	132.88	140.54	120.85	123.71	86.77	72.59	84.83	81.02	69.45	67.96	77.22	1164.90
Total Monthly Precipitation 2023	3.40	2.29	7.39	2.40									15.48
Total Monthly Precipitation 2022	1.97	5.87	4.9	4.52	7.72	2.05	2.43	6.55	3.13	1.41	2.25	3.58	46.38
				<u>.</u>									
2023 Monthly Percent Capacity	96%	86%	133%	79%									99%
Actual Design Flow 4.0 MGD		•	•			•							

Sewer Crew Activities

- 1. Performed 11 lateral inspections.
- 2. Completed routine maintenance and lift station checks.
- 3. Responded to 19 service calls: homeowners and lift stations.
- 4. Cleaned and inspected 3515 feet of sanitary and 205 feet of storm mainlines.
- 5. Repaired sinkhole at McKenzie and Potts Ditch and at bowling alley entrance.
- 6. Repaired/replaced 75 feet of storm mains.
- 7. Installed 3 new storm structures.
- 8. Repaired 14 storm structures.
- 9. Completed site dirt work at various work sites.

Plant Crew Activities

Sludge Pressed / Gallons: 929,900

Plant Operations and Maintenance:

- 1. Completed required monthly maintenance.
- 2. Hauled out 822 tons of bio-solids.
- 3. Started up the disinfection system.
- 4. Cemen Tech gearbox and shaft were re-installed and system is running again.
- 5. Repaired garage door on chemical building.
- 6. Replaced motor on west primary clarifiers (1 and 2).
- 7. Replaced muffler on sludge pump #3.
- 8. Starting processing sludge without adding flyash and seems to be working ok, but will have to send to landfill instead of distributing.

Monthly Overtime WWTP Operators Collection System Operators Scheduled: weekends, Emergnecy Call Ins Other Unscheduled **Emergency Call Ins** Other holidays 12.5 24.5 75.5 36.75 36.75 **Total Dept. Overtime:** 186