
## Wastewater Utility 2023 Monthly Report





Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
<b>Total MG Treated Effluent 2023</b>	119.40	96.16	164.80	95.29	88.73	67.40	85.80	89.80	70.30				877.68
Total MG Treated Effluent 2022	107.08	132.88	140.54	120.85	123.71	86.77	72.59	84.83	81.02	69.45	67.96	77.22	1164.90
<b>Total Monthly Precipitation 2023</b>	3.40	2.29	7.39	2.40	1.32	1.39	5.68	5.03	1.01				29.91
Total Monthly Precipitation 2022	1.97	5.87	4.9	4.52	7.72	2.05	2.43	6.55	3.13	1.41	2.25	3.58	46.38
2023 Monthly Percent Capacity	96%	86%	133%	79%	72%	56%	69%	72%	59%				80%
Actual Design Flow 4.0 MGD		•											

**Total Dept. Overtime:** 

53

Sewer Crew Activities			Plant Crew Act	tivities		
1. Performed 16 lateral inspections.	Sludge Presse	d / Gallons: 510,000				
2. Completed routine lift station checks.	Plant Operations and M	aintenance:				
3. Repaired 3 catch basins/manholes.	1. Completed required mont	hly maintenance.				
4. Completed video inspection of 820' of sanitary and 100' of storm mains.	2. Hauled 0 tons of Class A	bio-solids to farmers and 35.	77 tons of pressed sludge t	to the la		
5. Repaired/replaced 270' of sanitary mains.	3. Changed out chlorine pun	np tubing.				
6. Cleaned 2565' of sanitary and 650' of storms mains.	4. Installed new muffler on s	ludge pump #1 and a new di	aphragm on sludge #3.			
7. Began working on main replacement on Melody lane	5. Replace gasket on convey	5. Replace gasket on conveyor for cemen tech system.				
	6. Had Maddox in to repair t	he auger shaft on the cemen	tech mixing unit.			
	7. Cleaned final clarifiers.					
			Monthly Over	rtime		
		WWTP Operators				
	Scheduled: weekends,	Emorgonov Coll Inc	Other	TT.		
	holidays	Emergency Call Ins	Other	Ur		
	40	4	0			

ches	
Inches	
nches	
Inches	
ches	Effluent Flow Rate (MGD)
nches	Precipitation - Inches
ches	
nches	
ies	

## ies

e					
<b>Collection System Operators</b>					
Unscheduled	Emergency Call Ins	Other			
3	6	0			