

Charles Gill
Water Utility Manager
451 Meek Street
Greenfield, Indiana 46140



Mayor Chuck Fewell
Board of Works and Public Safety
10 South State St.
Greenfield, IN 46140

Re: Emergency Repair

August 25, 2020

Mayor and Board Members,

On August 12th, we found a minor leak in the South Plant Chlorine manifold system. This system is comprised of two sections that provide chemical feed to disinfect the water before entering the distribution system. Fortunately, the bank of chlorine cylinders were empty and was isolated to prevent any potential issue. This manifold is not in production currently and as such we must replace it with the current unit that is available. As this is a critical system I authorized the purchase and installation of the new manifold to restore the system to full operational status. The cost of this repair was \$3524.16. I welcome any questions the Board may have on this course of action.

Respectfully Submitted,

A handwritten signature in black ink, appearing to read "Charles Gill", is positioned above the typed name.

Charles Gill
Manager
Water Utility

cc: Mike Fruth, Utility Director
Dan Worl, Business Service Manager
Lori Elmore, Clerk-Treasurer